



# Annual WATER QUALITY REPORT

Presented by  
Harrisonburg VA Public Utilities  
PWS ID# 2660345

Reporting Year 2015

## Dear Valued Customer:

Harrisonburg Public Utilities is proud to be your local water service provider and is pleased to share some very good news about the quality of your drinking water. As you read through our Annual Water Quality Report, you will see that we continue to supply water that meets or surpasses all state and federal water quality standards. Better yet, the price you pay for this high-quality water service remains less than a penny per gallon.

This is an exceptional value when you consider the facilities and technology needed to draw water from the source and treat it, along with the miles and miles of pipeline hidden below the ground to bring water to your tap. What's more, our plant operators and field maintenance crews work around the clock to make sure that quality water is always there when you need it.

Because water is essential for public health, fire protection, economic development, and overall quality of life, Harrisonburg Public Utilities employees are committed to ensuring that quality water keeps flowing not only today but well into the future. We hope you agree that your water service is worth every penny.

Please take the time to review this report. It provides details about the source and quality of your drinking water using data from water quality testing conducted on our water system between January and December 2015. Thanks for allowing us to serve you.

If you have questions about this report or want additional information about the quality of your drinking water, please contact our Engineering Superintendent, David Gray at 540.434.9959.

## Asset Management

The American Society of Civil Engineers recently gave a near failing grade of D Minus to the U. S. nation's drinking water infrastructure.

Harrisonburg's water and sewer infrastructure is not so bleak since there are many new installations and modern technology is integrated throughout the water and sewer system as economically possible. However, the City's \$200 million of water assets and \$87 million of sewer assets are not without concern as some date as old as the late 1800s.

To remain strong and viable, Harrisonburg Public Utilities is promoting and engaging

much emphasis to an asset management program. This is a combination of management, economic, scientific, engineering, and other practices applied to physical assets with the objective of providing the required level of service in the most cost effective manner.

Mike Collins  
Director Public Utilities



# Definitions

**AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MRDL (Maximum Residual Disinfection Level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG (Maximum Residual Disinfection Level Goal):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**NA:** Not applicable

**ND (Not Detected):** Indicates that the substance was not found by laboratory analysis.



**NTU (Nephelometric Turbidity Unit):** Measure of water clarity. Turbidity in excess of five NTUs is barely noticeable to the average person.

**Ppb (parts per billion):** One part substance per billion parts water (or micrograms per liter).

**Ppm (parts per million) or mg/l (milligrams per liter):** One part substance per million parts water or milligrams per liter.

**TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.



## Where does your water come from?

The City of Harrisonburg has two reliable water supply sources. The Dry River in Rawley Springs is a surface water source. The watershed includes the Switzer Reservoir Impoundment, which can supply the piping network at capacity with 4 million gallons per day (except during drought) of highest quality water at the most cost-effective price. The North River in Bridge-water is also a surface water source and provides up to 7.5 million gallons per day and

5.5 million gallons per day during drought. The water quantity and quality of North River fluctuates due to runoff conditions at the withdrawal site. Because our treatment facility has the capacity to provide 15 million gallons of clean drinking water every day, we are in the process of developing a supply line from the South Fork Shenandoah River. Once this project has been completed, we expect to provide a supply of 15 million gallons per day to our customers.

## Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

**Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides & Herbicides**, which may come from a variety of sources, such as agriculture, urban storm water runoff and residential uses.

**Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban storm water runoff and septic systems.

**Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities. For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at **(800) 426-4791**.

# Sampling Results

Contaminants detected January 2015 through December 2015

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

Regulated Substances							
Substance (Unit of Measure)	Year Sampled	MCL [MRDL]	MCLG [MRDLG]	Amount Detected	Range Low-High	Violation	Typical Source
Barium (ppm)	2015	2	2	0.036	NA	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Haloacetic Acids [HAA] (ppb)	2015	60	NA	23.0	8-40	No	By-product of drinking water disinfection
Nitrate (ppm)	2015	10	10	1.32	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2015	80	NA	37.0	12-56	No	By-product of drinking water disinfection
Total Coliform Bacteria (% positive samples)	2015	5% of monthly samples are positive	0	1 positive sample in 2015 (2%)	NA	No	Naturally present in the environment
Total Organic Carbon (mg/L)	2015	TT	NA	NA	0.46-1.04	No	Naturally present in the environment
Turbidity <sup>1</sup> (NTU)	2015	TT	NA	NA	0.03-0.12	No	Soil Runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2015	<0.3 NTU	NA	100%	NA	No	Soil Runoff
Radiological							
Beta Emitters (mrem/yr)	2010	4	0	< 1.2	NA	No	Decay of natural and man-made deposits
Alpha Emitters (pCi/l)	2010	15	0	< 0.4	NA	No	Erosion of natural deposits
Combined Radium(pCi/l)	2010	5	0	< 0.4	NA	No	Erosion of natural deposits
Substance (Unit of Measure)	Year Sampled	AL	MCLG	Amount Detected (90th% tile)	Sites Above AL/Total Sites	Violation	Typical Source
Copper <sup>2</sup> (ppm)	2013	1.3	1.3	< 0.02	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead <sup>2</sup> (ppb)	2013	15	0	< 0.02	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Secondary Substances							
Substance (Unit of Measure)	Year Sampled	SMCL	MCLG	Amount Detected	Range Low-High	Violation	Typical Source
Fluoride (ppm)	2015	4	4	NA	0.58-1.04	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

<sup>1</sup> Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system.

<sup>2</sup> Tap water samples were collected for lead and copper analyses from sample sites throughout the community.

## Other Water Qualities of Interest

### Is my water hard or soft?

Water is soft when it falls from the sky as rain. It readily dissolves minerals as it travels through rock and soil. The treatment process removes some of the mineral content and impurities, but calcium and magnesium will generally not be removed. These minerals are not harmful to your health. The U.S. Geological Survey uses the following ranges of measurements to classify water into hard and soft water:

In 2015, our water was between 17-118 mg/l (milligrams per liter) which would be soft to moderately hard.

You should not have scale build-up or have to use additional soap for laundry or other washing purposes.

Classification	Hardness in mg/L
Soft	0-60
Moderately Hard	61-120
Hard	121-180
Very Hard	≥ 181

### What is the pH of my water?

pH is measured on a scale of 0 to 14. Water with values lower than 6 are acidic and can have aesthetic problems such as a metallic or sour taste. Water with values greater than 8.5 is less corrosive to metal piping and efficiency with chlorine disinfection decreases.

While the ideal pH level of drinking water should be between 6-8.5, the human body maintains pH equilibrium on a constant basis and will not be affected by water consumption.

For example our stomachs have a naturally low pH level of 2, which is a beneficial acidity that helps us with food digestion.

In 2015, our pH levels were between 7.1 and 10.0.

pH Examples	
Substances	pH
Apple Juice	3.0
Orange Juice	3.5
Coffee	5.5
Milk	6.2
Baking Soda	8.5
Soapy Water	10.0

MARKET ANALYSIS OF WATER AND SEWER RATES AMONG WATER SYSTEMS OF 10,000-30,000 RESIDENTIAL WATER UNITS 5,000 GALLONS WATER AND SEWER CONSUMPTION				
UTILITY PROVIDER	RESIDENTIAL WATER UNITS	WATER \$/5000 GAL	SEWER \$/5000 GAL	W & S RATE \$/5000 GAL
City of Harrisonburg	14,536	13.38	27.60	40.98
City of Danville	15,015	24.93	31.29	56.22
Spotsylvania County	27,805	29.53	29.11	58.64
James City Service Authority	19,848	14.76	44.21	58.97
Hanover County	18,290	21.82	38.06	59.88
Town of Leesburg	16,021	29.43	32.51	61.94
City of Lynchburg	22,000	19.41	43.45	62.86
Frederick Co. Sanitation Auth.	13,460	28.26	35.83	64.09
Henry County Public Service Auth	12,483	34.70	34.70	69.40
Albermarle Co Service Auth.	23,105	34.00	40.50	74.50
Bedford Regional Water Authority	11,623	29.30	47.25	76.55
Augusta Co. Service Auth.	16,033	32.42	53.67	86.09
City of Charlottesville	13,123	39.09	51.19	90.28
Washington Co Service Auth.	19,307	44.80	66.33	111.13
Virginia Control Group Average		30.77	40.37	71.14

This Control Group is comprised of 20 water and wastewater providers who represent a cross section of utilities across the Commonwealth. *Courtesy of Draper Aden Associates 2015 Study*

## Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Dis-

ease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791 or at <http://water.epa.gov/drink/hotline>.



## Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Harrisonburg Public Utilities Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water



has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Source Water Assessment

A Source Water Assessment for the City of Harrisonburg was completed by the Virginia Department of Health on May 24, 2002. This assessment determined that the city's water sources, North River and Dry River, are surface waters exposed to a

wide array of changing hydrologic, hydraulic, and atmospheric conditions. More specific information may be obtained by contacting the Harrisonburg Department of Public Utilities at (540) 434-9959.

## Featured Program: F O G

FOG (Fats, Oils, and Grease) comes from meats, butters, food scraps, sauces, dressings, dairy products and cooking oil. When FOG goes down the drain it hardens and will cause the sewer pipes to clog. Commercial additives, including detergents, that claim to dissolve grease only pass grease down the line and cause problems in other areas.

The hardened grease can lead to a sanitary sewer overflow where raw sewage actually backs up into your home, lawn, and neighborhood. The cleanup is expensive and unpleasant. Call us first at 434-9959 if you have a back up on your property or see an overflow occurring in your area, we will dispatch a crew promptly.

Keeping the grease out of the sewer pipes will help you, your community, and help your public utility keep operation and maintenance costs down.

Simple things you can do:

- Don't pour cooking oil down the sink.
- Scrape leftover food & sauces from your plate into the trash.



***“Think trash not toilets”***

Avoid damaging your household plumbing by putting the following items in the trash: cleaning wipes, disposable diapers, dental floss, band-aids, cotton balls, tampons/pads, and condoms.

***Prevention is the key.***

***Keep your pipes and drains “fat-free”.***