



ADDENDUM #3
RFP NUMBER: 2014005-PU-P
North River Pump Station Motor Replacement RFP
PROJECT 473-12-13
CONTRACT 3

DATE: January 6, 2014

TO: All Potential Proposers

City of Harrisonburg's North River Pump Station Motor Replacement RFP (2014005-PU-P), is modified as follows:

1. Question: After reviewing the addendum the drawings are showing a 350 Hp @480 volt. According to bid documents they are 400. Please confirm.

Answer: Drawings were provided for installation reference not as specification as they were in draft form at the time; the motors are to be 400 HP as specified in the RFP core document.

End of Addendum No. 3

All other requirements, terms and conditions of the RFP remain unchanged.

Addendum page must be signed and returned with your proposal to acknowledge receipt of this addendum.

Authorized Signature

By: Pat Hilliard, CPPB
Purchasing Agent