



**ADDENDUM #1**  
**ITB/RFP NUMBER: 20170013-PW-B**  
**Bluestone Trail**

DATE: October 27, 2016

TO: All Potential Bidders/Offerors

- 1. Question: Is there a certain way JMU wants the lighting to be maintained for the sidewalk/roadway on the project?**

Answer: JMU has requested that lighting must be maintained at the current light level present on site.

- 2. Question: Will regular excavation and fill line items be paid for at the unit prices?**

Answer: Yes. The pay items will be paid for and measured as they appear on the bid tab. Significant errors found by contractors during the bidding process need to be brought to the City's attention immediately.

- 3. Question: Is the excavation unclassified?**

Answer: Yes

- 4. Question: Are VDOT standards being used for the pavement markings?**

Answer: Yes.

- 5. Question: Is it alright to put safety fence around the entire project? Or does JMU prefer to just have the safety fence only where work is being performed?**

Answer: The contractor may place the safety fence only where there is activity or he may fence off the entire project.

**6. Question: Will the CADD files be made available for bidding?**

Answer: No. They will be available to the successful contractor once the project is awarded.

**7. Question: Are there any details on the steam vault vent?**

Answer: The plans provide sufficient notes concerning the intent of the design around the steam vault vent. If needed the contractors may contact JMU directly to visit the site and inspect the steam vault in this area.

**8. Question: Do the parking lot pavement markings need to have glass beads?**

Answer: No.

All other requirements, terms and conditions of the ITB/RFP remain unchanged.

Addendum page must be signed and returned with your bid/proposal to acknowledge receipt of this addendum.

---

Authorized Signature

By: Pat Hilliard, CPPB  
Procurement Manager

PRE-BID MEETING ATTENDANCE  
 Bluestone Trail Extension Project  
 Tuesday, October 25, 2016

NAME (Please Print)	COMPANY	PHONE/FAX	EMAIL
Daniello Morris	City	434-5928	Daniello.Morris@harrisonburgva.gov
Ben Swareg	Partners Excavating	433-1475	benepartners-excavating.com
Tom Lever	Fielder's Choice Enterprises, Inc.	David Thornton, Snr. Est. (434) 962-3573	Estimating@FCE-Digs.com
Jeff Gordon	Mid Valley Electric Inc	540-433-8815 F 540-433-5599	jgordon@midvalleyelectric.net

PRE-BID MEETING ATTENDANCE  
 Bluestone Trail Extension Project  
 Tuesday, October 25, 2016

NAME (Please Print)	COMPANY	PHONE/FAX	EMAIL
Sergio Yabeta	Public Works	(540) 476 3039	Sergio.Yabeta@harrisonburgva.gov
Abe Kantman	JMU	540.568.4201	Kantman@jmu.edu
Robert Weese	JMU	540 368 4376	Wweesern@jmu.edu
Tyson Rosser	VHB	757.490.0132	TROSSER@VHB.COM
Tom Hartman	City	540-434-5928	Tom.Hartman@harrisonburgva.gov