



ADDENDUM #4

ITB/RFP NUMBER: 2019008-PW-B

Main Street Streetscape Phase III ITB (EN15-115-106)

DATE: January 9, 2019

TO: All Potential Bidders/Offerors

The City of Harrisonburg's Main Street Streetscape, Phase III ITB is modified as follows:

On Addendum #3, the response to Question #4 was not completely answered. Below is a repeat of the question, the initial answer provided in Addendum #3 and the additional information requested regarding the foundation that was not directly answered previously.

4. Question: The plan sheet states that the new signal pole and foundation will be installed in the same place as the old one. This will be difficult to conduct a test bore. Also, the contractor will need to have the foundation design for the existing signal pole to correctly estimate the removal of the foundation. The new foundation should be installed far enough away from the existing foundation so there will not be any caving.

Answer: The test bores will need to be taken within 5 feet of the proposed signal pole locations. We do not have foundation designs for these intersections.

All other requirements, terms and conditions of the ITB/RFP remain unchanged.

Addendum page must be signed and returned with your bid/proposal to acknowledge receipt of this addendum.

Authorized Signature

By: Pat Hilliard, CPPB
Procurement Manager